太阳能产品认证证书

证书编号： CQC17024163145

申请人名称及地址

江西兆能新能源科技有限公司

江西省抚州市东乡县渊山岗工业园区南京路17号

制造商名称及地址

江西兆能新能源科技有限公司

江西省抚州市东乡县渊山岗工业园区南京路17号

生产企业名称及地址

上海兆能电力电子技术有限公司 (V020167)

上海市嘉定区纬五路188号2幢2层

产品名称和系列、规格、型号

太阳能光伏逆变器

CNT36KTL，CNT50KTL，CNT50KTL-C1

产品标准和技术要求

NB/T32004-2013（IIIa，不含低电压穿越试验）

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC33-461239-2013认证规则的要求，特发此证。

发证日期： 2017年04月19日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2017年02月16日

主任：

中国质量认证中心

中国·北京·南四环西路188号9区100070

http://www.cqc.com.cn

T 0006507

SOLAR PRODUCT CERTIFICATE

No.: CQC17024163145

NAME AND ADDRESS OF THE APPLICANT

Jiangxi Trannergy New Energy Technology Co., Ltd.
No.17, Nanjing Road, Yuanshangang Industry Park, Dongxiang, Fuzhou, Jiangxi

NAME AND ADDRESS OF THE MANUFACTURER

Jiangxi Trannergy New Energy Technology Co., Ltd.
No.17, Nanjing Road, Yuanshangang Industry Park, Dongxiang, Fuzhou, Jiangxi

NAME AND ADDRESS OF THE FACTORY

Trannergy Co., Ltd. (V020167)
Floor 2, Building 2, No.188, Weiwu Road, Jiading District, Shanghai

NAME, MODEL AND SPECIFICATION

Solar Gird Connected Inverter

CNT36KTL，CNT50KTL，CNT50KTL-C1

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

NB/T32004-2013(IIIa,Without Low Voltage Ride Through Test)

CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules CQC33-461239-2013.

Date of issue: Apr.19,2017

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Feb.16,2017

President: Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
http://www.cqc.com.cn

T 0006507

太阳能产品认证证书

附录：　　第 1 页 共 1 页

证书编号：CQC17024163145　　纸号：6507

CNT36KTL

直流输入：MPPT 追踪电压范围 DC200V-1000V，最大支路输入电压 DC1100V，

最大输入电流 22A × 4；交流输出：3(N) ~ 380V，50Hz，60.8A，额定交流输出功率 36kW.

CNT50KTL

直流输入：MPPT 追踪电压范围 DC200V-1000V，最大支路输入电压 DC1100V，

最大输入电流 22A × 4；交流输出：3 ~ 480V，50Hz，60.8A，额定交流输出功率 46kW.

CNT50KTL-C1

直流输入：MPPT 追踪电压范围 DC200V-1000V，最大支路输入电压 DC1100V，

最大输入电流 22A × 4；交流输出：3 ~ 500V，50Hz，60.8A，额定交流输出功率 47.5kW.

注：此附录与证书同时使用时有效。

主任：

中国质量认证中心

中国　北京　南四环西路 188 号 9 区 100070

http://www.cqc.com.cn